

# CITY OF NEWTON, MASSACHUSETTS

## PURCHASING DEPARTMENT

[purchasing@newtonma.gov](mailto:purchasing@newtonma.gov)

Fax (617) 796-1227

March 16, 2012

## ADDENDUM #2

### INVITATION FOR BID #12-49

### ANNUAL – FIRE SPRINKLER & RELATED SYSTEMS

THIS ADDENDUM IS TO: **Answer the following Questions:**

Q1. Under 1.01, Section C.1: Inspection frequency on gauges is requested at weekly /monthly. Does the city require the sprinkler company to do a weekly/monthly inspection of all gauges?

**A1. Monthly, along with any other monthly required inspections.**

Q2. Will the 5 year obstruction tests be done for all systems during year 1 of the contract?

**A2. Yes**

All other terms and conditions of this bid remain unchanged.

**PLEASE ENSURE THAT YOU ACKNOWLEDGE THIS ADDENDUM ON YOUR BID FORM.**

Thank you.

*Purchasing Department*